

Expert's reports

Skid resistance measurements*

ESD/ATEX floor measurements*

Van Aarle Houtbedrijf B.V.
 Ollandseweg 159
 5491 XB Sint-Oedenrode

Druuten, February 9, 2018

Product: WOODGRIP 3

Measuring site: Van Aarle Houtbedrijf B.V. Sint-Oedenrode (MIJtech report 18.0058 rv1)

Product Certificate: C18.0058c
Product: WOODGRIP 3
Skid resistance of floors: NEN-EN 13036-4



On the basis of the measurements carried out on January 26, 2018 and the results obtained thereby, the product WOODGRIP 3 meets all requirements of the (Dutch) NEN 2443 standard on parking facilities for passenger cars in parking lots and parking garages, and properties of road and airport surfaces.

no.	Location: 1 WOODGRIP 3										average	average
	1		2		3		4		5			
	dry	wet	dry	wet	dry	wet	dry	wet	dry	wet	dry	wet
	145	85	145	85	148	85	145	85	150	86	146,60	85,20

NEN 2443 (Dutch) Parking facilities for passenger cars in parking lots and parking garages: SRT wet at least 65.
Properties of road and airport surfaces (wet) SRT at least 55.

Woodgrip 3: meets the aforementioned requirements.

The product must be applied in conformity with the advice and guidelines of the supplier/producer.

This certificate is based on the information given in the MIJtech report 18.0058 rv1, of 30-01-2018.

The measurements only constitute a snapshot in time. The report is of overriding importance for the award of the certificate. Calibrated measuring equipment was used.



Due to use, circumstances and wear, the floors' properties may change.

It is assumed that the floor will neither be modified nor provided with a new layer, and that it will be both cleaned properly and used normally.

René Mijling

sr. Advisor / expert in casting floors